

Clinical Laboratory of San Bernardino, Inc.

Celebrating 50 Years of Analytical Service 1967-2017



Weber Valley Heights
44350 Benton Rd.
Hemet CA, 92544

Project: Routine
Sub Project:
Project Manager: Water Quality Supervisor

Work Order: 24J0880
Received: 10/08/24 10:51
Reported: 10/11/24

Well 1 - Franko Res

24J0880-01 (Water)

Sample Date: 10/08/24 8:10

Sampler: Debbi St. Pierre

Analyte	Method	Result	Rep. Limit	MCL	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	-----	-------	----------	----------	-------	-----------

Microbiology Analyses

Total Coliform	SM 9223	A			P/A	10/08/24	10/09/24	2441108	
E. Coli	SM 9223	A			P/A	10/08/24	10/09/24	2441108	

General Chemical Analyses

Nitrate as N (NO3-N)	EPA 300.0	2.3	0.40	10	mg/L	10/08/24	10/08/24	2441055	
----------------------	-----------	-----	------	----	------	----------	----------	---------	--

Well 2- Faucet at Tank

24J0880-02 (Water)

Sample Date: 10/08/24 8:20

Sampler: Debbi St. Pierre

Analyte	Method	Result	Rep. Limit	MCL	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	-----	-------	----------	----------	-------	-----------

Microbiology Analyses

Total Coliform	SM 9223	A			P/A	10/08/24	10/09/24	2441108	
E. Coli	SM 9223	A			P/A	10/08/24	10/09/24	2441108	

General Chemical Analyses

Nitrate as N (NO3-N)	EPA 300.0	2.3	0.40	10	mg/L	10/08/24	10/08/24	2441055	
----------------------	-----------	-----	------	----	------	----------	----------	---------	--

ND Analyte NOT DETECTED at or above the reporting limit

Isabel Navarro
Assistant PM

